



GREAT LAKES SCALE COMPANY
 29540 CALAHAN RD.
 ROSEVILLE, MI 48066
 Phone: (586) 776-0517

Customer: SUPERIOR MATERIALS 103
 SUP0992 10147 GRAND RIVER
 BRIGHTON, MI 48116

Certificate ID: 23635-c180312123334
Test Date: 03/12/2018
ISO Number: MS-FM-CEM-001

TEST INFORMATION

TEST WEIGHT CLASSIFICATION	EXPANDED UNCERTAINTY
F	3.39
ENVIRONMENTAL CONDITIONS	TEMPERATURE
Acceptable	40
WAS THE SCALE WITHIN CUSTOMERS REQUIRED ACCURACY?	
Yes	
TEST LOCATION	OVERALL RESULT
Onsite	Pass adjustment needed

Comments:

Test and cal scale

TRACEABILITY CERTIFICATE NUMBERS:				
Kit	NIST	Date	Date Due	
Description				
GL0601	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0602	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0603	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0604	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0605	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0606	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				

Technician(s): RENTE EVANS; Joe bielarz

Signature:

Devices were calibrated with the certified test weights. Adjustments made to restore and/or maintain the accuracy of the device conform to the tolerances established by NIST or Manufacturers Specifications. Best measurement of uncertainty calculated using a coverage factor of K=2. This provides confidence level of 95%.



GREAT LAKES SCALE COMPANY
29540 CALAHAN RD.
ROSEVILLE, MI 48066
Phone: (586) 776-0517

Certificate of Calibration

Customer: SUPERIOR MATERIALS 103
SUP0992 10147 GRAND RIVER

Certificate ID: 23635-c180312123334

Test Date: 03/12/2018

BRIGHTON, MI 48116

ISO Number: MS-FM-CEM-001

(*Make: ALKON Model : COMMAND SN#: 23625-c Capacity: 4000 LB Graduation: 5 LB

CALIBRATION DATE 03/12/2018	DUE DATE 09/11/2018	TEST INTERVAL Semi-Annually	SCALE ID 23635-c	SCALE CLASS III
SCALE LOCATION Water scale		EQUIPMENT CONDITIONS Working Clean		
SELECT NUMBER OF PM DAYS:	CAPACITY	4000 UOM	LB	INCREMENT
				5

AS FOUND TEST USING TEST WEIGHTS

AS LEFT TEST USING TEST WEIGHTS

Weight Applied	Reading	Error	Weight Applied	Reading	Error
0	LB 0	LB 0	0	LB 0	LB 0
1000	LB 995	LB -5	1000	LB 1000	LB 0
2000	LB 1990	LB -10	2000	LB 1995	LB -5
3000	LB 2990	LB -10	3000	LB 2995	LB -5
4000	LB 3985	LB -15	4000	LB 3995	LB -5
0	LB 0	LB 0	0	LB 0	LB 0
	LB	LB		LB	LB
	LB	LB		LB	LB
	LB	LB		LB	LB
	LB	LB		LB	LB

AS LEFT BUILD TEST

Test Weight Applied	Material Weight Applied	Reading	Error
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB
LB	LB	LB	LB

OVERALL TEST RESULTS **PASS**

JFB



GREAT LAKES SCALE COMPANY
 29540 CALAHAN RD.
 ROSEVILLE, MI 48066
 Phone: (586) 776-0517

Certificate of Calibration

Customer: SUPERIOR MATERIALS 103
 SUP0992 10147 GRAND RIVER

BRIGHTON, MI 48116

Certificate ID: 23635-a180312121622

Test Date: 03/12/2018

ISO Number: MS-FM-CEM-001

(*)Make: ALKON Model: COMMAND SN#: 23635-a Capacity: 10000 LB Graduation: 5 LB

CALIBRATION DATE 03/12/2018	DUE DATE 09/11/2018	TEST INTERVAL Semi-Annually	SCALE ID 23635-a	SCALE CLASS III
SCALE LOCATION Cement scale		EQUIPMENT CONDITIONS Working Clean		
SELECT NUMBER OF PM DAYS:		CAPACITY	10000 UOM	LB INCREMENT 5

AS FOUND TEST USING TEST WEIGHTS

AS LEFT TEST USING TEST WEIGHTS

Weight Applied	Reading	Error	Weight Applied	Reading	Error
0	LB 0	LB 0	0	LB 0	LB 0
1000	LB 1000	LB 0	1000	LB 1000	LB 0
2000	LB 2000	LB 0	2000	LB 2000	LB 0
3000	LB 2995	LB -5	3000	LB 2995	LB -5
4000	LB 4000	LB 0	4000	LB 4000	LB 0
5000	LB 4995	LB -5	5000	LB 4995	LB -5
6000	LB 6000	LB 0	6000	LB 6000	LB 0
0	LB 0	LB 0	0	LB 0	LB 0
	LB	LB		LB	LB
	LB	LB		LB	LB

AS LEFT BUILD TEST

Test Weight Applied	Material Weight Applied	Reading	Error
6000	LB 3300	LB 9300	LB 0
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB
		LB	LB

OVERALL TEST RESULTS PASS



GREAT LAKES SCALE COMPANY
 29540 CALAHAN RD.
 ROSEVILLE, MI 48066
 Phone: (586) 776-0517

Customer: SUPERIOR MATERIALS 103
 SUP0992 10147 GRAND RIVER
 BRIGHTON, MI 48116

Certificate ID: 23835-a180312121622
Test Date: 03/12/2018
ISO Number: MS-FM-CEM-001

TEST INFORMATION

TEST WEIGHT CLASSIFICATION	EXPANDED UNCERTAINTY
F	3.68
ENVIRONMENTAL CONDITIONS	TEMPERATURE
Acceptable	40
WAS THE SCALE WITHIN CUSTOMERS REQUIRED ACCURACY?	
Yes	
TEST LOCATION	OVERALL RESULT
Onsite	Pass w/o adjustment

Comments:
 Test scale was good

TRACEABILITY CERTIFICATE NUMBERS:			
Kit	NIST	Date	Date Due
Description			
GL0601	MI-06-17-13260	6/15/2017	6/15/2019
TRUCK 6 - 1000 LB			
GL0602	MI-06-17-13260	6/15/2017	6/15/2019
TRUCK 6 - 1000 LB			
GL0603	MI-06-17-13260	6/15/2017	6/15/2019
TRUCK 6 - 1000 LB			
GL0604	MI-06-17-13260	6/15/2017	6/15/2019
TRUCK 6 - 1000 LB			
GL0605	MI-06-17-13260	6/15/2017	6/15/2019
TRUCK 6 - 1000 LB			
GL0606	MI-06-17-13260	6/15/2017	6/15/2019
TRUCK 6 - 1000 LB			

Technician(s): RENTE EVANS; Joe bielarz

Signature:

Devices were calibrated with the certified test weights. Adjustments made to restore and/or maintain the accuracy of the device conform to the tolerances established by NIST or Manufacturers Specifications. Best measurement of uncertainty calculated using a coverage factor of K=2. This provides confidence level of 95%.



Certificate of Calibration

Certificate ID: 23635-b180312122712

Customer: SUPERIOR MATERIALS 103
 SUP0992 10147 GRAND RIVER

Test Date: 03/12/2018

BRIGHTON, MI 48116

ISO Number: MS-FM-CEM-001

(*Make: ALKON Model : COMMAND SN#: 23635-b Capacity: 45000 LB Graduation: 20 LB

CALIBRATION DATE 03/12/2018	DUE DATE 09/11/2018	TEST INTERVAL Semi-Annually	SCALE ID 23635-b	SCALE CLASS III L
SCALE LOCATION Agg scale		EQUIPMENT CONDITIONS Working Clean		
SELECT NUMBER OF PM DAYS:		CAPACITY	45000 UOM	LB INCREMENT 20

AS FOUND TEST USING TEST WEIGHTS

AS LEFT TEST USING TEST WEIGHTS

AS FOUND TEST USING TEST WEIGHTS			AS LEFT TEST USING TEST WEIGHTS		
Weight Applied	Reading	Error	Weight Applied	Reading	Error
0	LB 0	LB 0	0	LB 0	LB 0
1000	LB 1000	LB 0	1000	LB 1000	LB 0
2000	LB 2000	LB 0	2000	LB 2000	LB 0
3000	LB 3000	LB 0	3000	LB 3000	LB 0
4000	LB 4000	LB 0	4000	LB 4000	LB 0
5000	LB 5000	LB 0	5000	LB 5000	LB 0
6000	LB 6000	LB 0	6000	LB 6000	LB 0
0	LB 0	LB 0	0	LB 0	LB 0
	LB	LB		LB	LB
	LB	LB		LB	LB

AS LEFT BUILD TEST

Test Weight Applied	Material Weight Applied	Reading	Error
6000	LB 8000	LB 14000	LB 0
6000	LB 16000	LB 22000	LB 0
6000	LB 24000	LB 30000	LB 0
6000	LB 32000	LB 38000	LB 0
6000	LB 38000	LB 44000	LB 0
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB
	LB	LB	LB

OVERALL TEST RESULTS PASS



GREAT LAKES SCALE COMPANY
 29540 CALAHAN RD.
 ROSEVILLE, MI 48066
 Phone: (586) 776-0517

Customer: SUPERIOR MATERIALS 103
 SUP0992 10147 GRAND RIVER
 BRIGHTON, MI 48116

Certificate ID: 23635-b180312122712
Test Date: 03/12/2018
ISO Number: MS-FM-CEM-001

TEST INFORMATION

TEST WEIGHT CLASSIFICATION	EXPANDED UNCERTAINTY
F	15
ENVIRONMENTAL CONDITIONS	TEMPERATURE
Acceptable	40
WAS THE SCALE WITHIN CUSTOMERS REQUIRED ACCURACY?	
Yes	
TEST LOCATION	OVERALL RESULT
Onsite	Pass w/o adjustment

Comments:
 Test scale. Perform build test

TRACEABILITY CERTIFICATE NUMBERS:				
Kit	NIST	Date	Date Due	
Description				
GL0601	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0602	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0603	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0604	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0605	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				
GL0606	MI-06-17-13260	6/15/2017	6/15/2019	
TRUCK 6 - 1000 LB				

Technician(s): RENTE EVANS; Joe bielarz

Signature:

Devices were calibrated with the certified test weights. Adjustments made to restore and/or maintain the accuracy of the device conform to the tolerances established by NIST or Manufacturers Specifications. Best measurement of uncertainty calculated using a coverage factor of K=2. This provides confidence level of 95%.