



This letter is to certify that the following Master Builders Solutions dispensing systems installed at this location were tested and meet the specifications of ASTM C-94 section 9.4.

ASTM C-94 section 9.4: Chemical admixtures in powdered form shall be measured by mass. Liquid chemical admixtures shall be batched by mass or volume. Admixtures measured by either mass or volume, shall be batched with an accuracy of plus or minus 3 % of the total amount required or plus or minus the amount or dosage required for 100 lb [50 kg] of hydraulic cement, whichever is greater.

ADMIXTURE (PRODUCT NAME)	TARGET AMOUNT	ACTUAL READING	PERCENT VARIANCE
1. MasterAir AE 200	40 oz	40 oz.	----
2. Masterpozzolith 200	50 oz.	50 oz.	----
3. Masterpolyheed 997	32 oz.	32 oz.	-----
4. MasterPolyheed 100	32 oz	32 oz.	----
5. MasterRheobuild 1000	110 oz.	110 oz.	----
6. MasterSet AC 534	128 oz	128 oz.	----
7. MasterLife CI 30	-----	-----	----
8. MasterSet Delvo	-----	-----	----
9. -----	-----	-----	-----
10. Water	100 gallons	100 gallons	

CUSTOMER:

PLANT LOCATION: Hoover Plant 02

TESTED AND APPROVED BY *Matt Umfress* DATE: 08/02/2021

CUSTOMER VERIFICATION BY: _____ DATE: _____